



May 2, 2013

ADDENDUM 1

TITLE: QUESTIONS AND ANSWERS

RFB 03637-NTT-00-GS-IT DATA CENTER AND CAMPUS MAINTENANCE

Attention: All Potential Bidders

ADDENDUM 1 "Questions and Answers" are submitted for your information in preparing responses to the above mentioned RFB.

ADDENDUM 1 "Questions and Answers" are hereby made a part of the contract for the aforementioned RFB. Bidders are required to acknowledge receipt of this addendum by checking the appropriate box on Vendor Information Page form, and submitting with your Bid. This Vendor Information Page form is a required part of a responsive bid submittal, due at the time your bid is submitted.

QUESTIONS AND ANSWERS:

1. On Page 9 of specifications (23 of 48) in the Horizontal Cable Testing section, the NTTA requests that the test equipment shall be the latest version of Fluke DSP 4300 series Testers. This seems to be an outdated tester and we would like clarification if a Fluke DTX 1800 Cable Analyzer will be acceptable for the Channel Tests required?

Vendors submitting bids can use the latest Fluke cable testers.

2. On page 25 of 48 - **V. COST PROPOSAL**, Item #s 6, 7, 8 & 9 request materials for Cable Network Drops. Could we possibly get an estimated or average run length incorporated into these line items so that all bid submissions can be evaluated on the same terms?

All vendors submitting a bid should base the calculation on an average cable network drop of 150 feet and Industry standard materials in their cost proposals.

This question and answer addendum does not change the due date for RFB 03637-NTT-00-GS-IT. Bids are due by 2:00PM CST on May 9, 2013. No late Bids will be accepted. If a conflict exists between the RFB and this addendum, the addendum prevails.

For any further inquiries, please email rwilliams2@ntta.org. The RFB number 03637-NTT-00-GS-IT should be included in the subject line of the email.

Thanks,

Ryan Williams,

Senior Buyer